

Issues In Wind Electric Distribution System and Different Mitigation Methods – A Perspective View

Radhamani V. Pillay¹, Vanitha V.², Anisha Asmy N.R.³

Abstract: Wind energy is one of the fastest-growing sources of electricity in India and around the world since it is economical, clean and abundant. There are two major types of wind generators, which are commonly used in wind farms. The first one is the squirrel cage induction generator while the second is doubly fed induction generator. In this, squirrel cage induction generator is widely used due to its low cost, low maintenance rate and possible utilization under wind gusting conditions. But wind farms with induction generators while generating real power, consume reactive power. Due to grid faults, the over speed of the induction generator resulted from transient currents drawn by the induction generator from the electrical power system can exceed the stability limit resulting in collapse of the system and islanding operation. Thus operators worldwide have developed new grid codes to integrate this form of generation. One important aspect of the problem is the low-voltage ride-through capability of wind generators. This paper gives a complete re-view of the power quality issues when using wind electric generators and different methods that are being used to mitigate these problems till date.

Keywords: wind electric generators, power quality issues, low voltage ride through, DVR, Super capacitor.

Introduction

Wind energy is one of the fastest-growing sources of electricity in India and around the world. In spite of being cheap, clean and abundant, the continuous fluctuations in the renewable energy causes significant power quality issues. People's confidence in wind power can easily be read from the rapidly growing figures. Worldwide installed wind power capacity reached 2, 82,482 MW, out of which 44,711 MW were added in 2012. The annual growth rate reached the highest of 31.7% since 2001 [1]. With the increasing penetration of wind energy and the improvement of technology, the operating characteristics of wind farms should be reconsidered carefully, especially during fault conditions. In this context, many countries have issued interconnection requirements for wind farms. Among these grid codes, two main issues are concerned, which of great relevance, are active and reactive power control in normal conditions and Low Voltage Ride-Through (LVRT) capability during grid fault. In fact, the grid code provides only standard requirements at the Point of Common Coupling (PCC). Different types of wind electric generators suffer in different ways due to the voltage dip in the grid.

The fixed speed wind turbines with induction generators are installed in the early age, which are cheap and reliable. But they do not have the ability to control active and reactive power flexibly. During grid faults, the wind turbines must be tripped to protect from damages due to over speed. This operation will cause load flow changing violently, even resulting in power system blackout when the wind farm is large and the grid is weak. The variable speed wind turbines are able to control the active and reactive power. But these devices are quite sensitive and need protection from overflow and impulse high voltage. A real problem faced by the wind turbine manufacturers, according to the new grid codes is

the wind plant's ability to ride-through a short-term low voltage at PCC [2].

Literature Survey

Modelling of Induction Generator and Power Quality Issues

M.G.Sugirtha and Dr. P.Latha give a technical review of power quality problems associated with grid connected wind power plant. They discuss about the different power quality issues in the grid side and wind electric generator side and also tell about the effects of those issues in the system [3]. K. C. Divya et al have detailed the possibility of using a simple model for grid connected induction generators [4] while studying the dynamic behaviour of such systems. In this method both the stator and rotor transients of the machines are neglected thus enabling the use of torque-slip characteristics of the induction machines, in the analysis of the dynamic behaviour. A concept of critical clearing slip has also been introduced and its utility has been highlighted.

The squirrel cage induction generators are used with many of the wind turbines, and since these units are incapable of generating reactive power, they cause serious problems in voltage stability of the network. A static voltage stability of the network with wind farm is analyzed by M. Vahedipour Dahræia et al by introducing a new index [5]. Sebastian S. Smater et al have introduced a framework for reliability and dynamic performance analysis of Wind Electric Conversion Systems (WECS), which will provide an overall measure of reliability for a particular WECS operating under all possible conditions, and subject to all possible faults in the WECS and the grid [6].

The modelling of Squirrel Cage Induction Generator (SCIG) and Doubly Fed Induction Generator (DFIG) based wind systems, including the turbine, the Field Orientation Control

of converters, and connection to the grid are presented by Yu Zou et al [7]. A STA-COM is applied to SCIG system to reduce voltage drop in distribution line. Comparison of SCIG performance with and without STACOM, as well as DFIG system clearly showed different results in the distribution line voltage. A focus on researching and discussing the impact of SCIG in distribution system, and finding the way out to supply higher power quality is studied by Ching-Yin Lee et al [8]. Case study includes choosing different connected location and installed capacity of wind generators and adopting fixed capacitors, SVC and STATCOM for compensation to observe the influence on the moment of the wind generator connected and the period of the wind speed variation.

2. Methods To Satisfy Low Voltage Ride Through (LVRT) Requirements

C. Rahmann et al have proposed an adaptive strategy to obtain technically justified Fault Ride Through (FRT) requirements for Wind Turbine (WT) based on system characteristics and on the wind power penetration level [9]. The proposal is specially aimed at countries with still low penetration levels of wind power, where the WT integration is carried out in a competitive environment without any kind of subsidies. Mital G. Kanabar et al have contributed towards the quantification of additional reactive power support necessary to satisfy LVRT requirements for the existing constant speed WTGs. To satisfy LVRT requirements of a constant speed WTG, the rotor speed stability margin has to be improved. For this, the formulae for critical slip and critical clearing time have been obtained analytically [10].

Shih-Feng Chou et al suggested a flux compensation method in [11] to mitigate the sag-induced flux offset, and hence reduce the potential post-sag inrush current. The proposed technique commands the converter current to meet the Reactive Current Injection (RCI) specifications of LVRT requirement, and to compensate the transformer flux offset.

Jose Luis Dominguez-Garcia et al have presented a control technique to deal with SCIG connected to the grid through a full power converter [12]. Both stator-side and grid-side are considered, which detail the control scheme to be used in each converter. The proposed indirect vector control strategy allows control the stator-side without flux sensor inside the machine, which assures less mechanical problems. Kyoung-Jun Lee et al have put forward a novel Low-Pass Notch filter PLL (LPN-PLL) control strategy to synchronize with the true phase angle of the grid instead of using a conventional Synchronous Reference Frame PLL (SRF-PLL), which requires a d-q -axis transformation of three-phase voltage and a proportional-integral controller [13].

Chia-Tse Lee et al have put forward an LVRT method to provide the required real power and reactive current without

exceeding the ampere limit of grid-connected interface converters [14]. This method consists of a positive and negative sequence current compensation control for the grid-connected converter to support AC grid voltages during the fault and to meet the LVRT requirement.

Ki-Hong Kim et al have come up with a low-voltage ride-through scheme for the Permanent Magnet Synchronous Generator (PMSG) wind power system at the grid voltage sag [15]. The dc-link voltage is controlled by the generator-side converter instead of the Grid-Side Converter (GSC). Considering the nonlinear relationship between the generator speed and the dc-link voltage, a dc-link voltage controller is designed using a feedback linearization theory. Po-Hsu Huang et al have introduced a novel shunt and series grid interface topologies of the GSC and transient management scheme to improve FRT capability for DFIG based wind turbines [16]. The system dynamics of the series compensation have been investigated and are represented by a small signal linear model, with which the controller is properly tuned to balance both voltage regulation performance and transient stability margins with consideration of various operating conditions.

Shuai Xiao et al have set forth a new flux-linkage tracking based LVRT control strategy [17] to suppress the short-circuit rotor current. Under the proposed control strategy, the rotor flux linkage is controlled to track a reduced fraction of the changing stator flux linkage by switching the control algorithm of Rotor Side Converter (RSC) during grid faults. Ebrahim Babaei and Mohammad Farhadi Kangarlu have introduced a new voltage sag compensator [18] which is based on the ac/ac direct converter. The converter in each phase is supplied from the other two phases of the grid and hence it does not face problem related to the required compensation power. The phase angle jump can be easily compensated by the proposed compensator. S.M. Muyeen et al have considered two-mass drive train model of WTGS [19] for the fault analysis of WTGS. Suitable control strategy of Energy Capacitor System (ECS) is developed to enhance the LVRT capability of WTGS. The performance of ECS during network fault is analysed by using the aggregated single generator model of wind farm.

Alvaro Luna et al have studied some control strategies for improving the FRT capability of a SCIG-WT, by means of controlling its full power processor located in its neighbourhood [20]. In order to analyse the feasibility of this proposal, their performance is tested and compared during fault and post-fault conditions. Jaume Miret et al have proposed a voltage controller to mitigate voltage sags based on the current scheme [21], which re-stores the dropped voltages to its continuous operation limits, thus guaranteeing LVRT and also increasing the stability of the power system. A detailed mathematical analysis of the injected currents during the voltage sag is also carried out in order to develop the proposed control.

Mohsen Rahimi and Mostafa Parniani have put forward

two coordinated ride-through approaches to fulfil the ride-through requirement in DFIG based wind turbines [22]. One approach is realized through the RSC control and by using additional equipment, called SDR. Second approach is realized through efficient control of GSC that effectively reduces the dc-link voltage fluctuation when the DFIG is subjected to a voltage drop. Manuel Reyes et al have analysed the double synchronous reference frame controller [23] and its structure is improved by adding a decoupling network for estimating and compensating the undesirable current oscillations. Jose Luis Dominguez-Garcia et al have selected an indirect field-orientation method [24]. This method is generally more dependant of the machine parameters, but it allows to work without necessity of Hall-Effect sensors which increment the cost of the system and reduce its robustness. The control applied is less dependent of the knowledge of machine behaviour.

3. Use of Dynamic Voltage Restorer

Jovica V. Milanovic and Yan Zhang have proposed a new methodology to financially analyze the investment in Flexible AC Transmission System (FACTS) devices to mitigate voltage sags by incorporating financial aspects of the problem [25]. Scenarios are evaluated with and without optimally placed FACTS devices. The capital investment cost and annual maintenance of devices over their life time is also considered. Jovica V. Milanovic and Yan Zhang presents have modeled three widely used FACTS devices (STATCOM, SVC and DVR) developed for large system fault analysis and static fault calculation studies [26]. Mathematical models of FACTS devices for symmetrical and asymmetrical fault studies are presented and incorporated in custom made system impedance matrix. H. M. Huang et al have proposed a study of applying STATCOMs to provide voltage support for offshore wind power plants to meet the LVRT requirement when connecting to the onshore power grid [27]. The required STATCOM capacity to meet voltage sag regulations imposed by grid codes for the investigated offshore wind power plant is also presented.

Hailian Xie et al have discussed the cost of a proposed interface system between an Energy Storage (ES) and a Voltage Source Converter (VSC) [28]. Mojtaba Nemati et al have described the role of the different parts of the Dynamic Voltage Restorer [29] and, the application of it has been evaluated. Theoretical concepts with practical results have also been compared. Naohiro Hasegawa and Teruhisa Kumano have studied LVRT capability enhancement of FSIG using DVR device [30] and it also proposes the method for decreasing the energy storage and inverter capacity of DVR. Bhim Singh et al have developed a new control algorithm [31] based on unit templates for the control of capacitor supported DVR for sag, swell, harmonics and unbalance in supply voltage. Hyunsik Jo et al have proposed a fast and robust sag detection algorithm for the line-interactive DVR [32], which calculates the fundamental and harmonic components by using the discrete Fourier transform and has a constant detection

response time regardless of phase angle at which sag occurs. During the sag compensation, a new selective harmonic mitigating method for voltage controller is proposed.

H. Gaztafna et al have set forth the contribution of a DVR compensator to the transient behaviour improvement of fixed-speed wind farms [33]. This analysis is carried out in real time reduced-scale test conditions in order to get as close as possible to real implementation conditions but minimizing costs and shortening the test process. N. Amutha et al have suggested a method based on the system equivalent circuit [34] to calculate the critical speed and Critical Clearing Time (CCT) of a SCIG based wind generator connected to grid. DVR has been used in this paper to improve CCT of the SCIG based wind generation system. O. Viktorin et al have discussed the topologies for the DVR with high frequency transformers [35]. This variant requires additional AC-AC converters in series with line voltages, making them less energy efficient. The proposed DVR topologies are designed in order to enable the elimination of zero sequence voltage components.

Tanonsak Keawsakunee and Paisan Boonchiam have discussed a detailed analysis of control strategies for medium voltage DVR for enhancing power quality [36]. A method of determining the exact amount of voltage injection required to correct a specific voltage reduction with minimum power injection is also described. Christoph Meyer et al have analysed different control strategies for a medium-voltage DVR [37]. First, a short description of the requirements on the DVR control has been given then three different control strategies has been described and compared.

Yan Li et al have developed control principles of the dual coupled inverters with super capacitor based energy storage, to achieve precise and fast response [38]. The control principles of each inverter of DVR are presented and the control principles of the DC/DC converter of the super capacitors are also explained. Long Hee Han et al have described the development of on-line type DVR whose reliability is superior [39]. EDLC (Electrical Double Layer Capacitor) that is profitable in capacitance, life cycle, stability, environmental side is used instead of electrolytic capacitor to store energy. R. Omar and N.A. Rahim have proposed a system which comprises of a super capacitor as energy storage, DC-DC converter, and the component of DVR [40]. The DVR components consist of a three phase inverter, filtering scheme and its controller. Digital signal processing (DSP) was used in order to produce the required control to DC-DC boost converter and Voltage Source Inverter (VSI). This system is capable to mitigate voltage disturbances at low voltage distribution system.

II. Conclusion

A Dynamic Voltage Restorer with supercapacitor as an energy storage can be used to satisfy the low voltage ride

through capability of wind electric generators and in mitigating other disturbances in the network. Thus a squirrel cage asynchronous wind generator will be able to remain connected to the grid during voltage sag with the aid of a DVR.

References

1. World Wind Energy Report, World Wind Energy Association (WWEA), 2010.
2. GONG Wenming, WANG Yun, HU Shuju, XU Honghua, "A Survey on Recent Low Voltage Ride-Through Solutions of Large Scale Wind Farm," Power and Energy Engineering Conference, 2011.
3. M.G.Sugirtha, Dr. P.Latha, "Analysis of Power Quality Problems in Grid Connected Wind Power Plant," International Conference on Recent Advancements in Electrical, Electronics and Control Engineering, 2011.
4. K. C. Divya, P. S. Nagendra Rao, "Study of dynamic behaviour of grid connected induction generators," Power Engineering Society General Meeting, 2004.
5. M. Vahedipour Dabraie, H. R. Najafi, M. Ebadian, "Analytical Investigation of the Effect of Wind Farm Equipped with SCIG on Voltage Stability," Second Iranian Conference on Renewable Energy and Distributed Generation, 2012.
6. Sebastian S. Smater, Alejandro D. Domínguez-García, "A Framework for Reliability and Performance Assessment of Wind Energy Conversion Systems," IEEE Transactions on Power Systems, vol. 26, no. 4, November 2011.
7. Yu Zou, Malik Elbuluk, Yilmaz Sozer, "A Complete Modelling and Simulation of Induction Generator Wind Power Systems," Industry Applications Society Annual Meeting (IAS), October 2010.
8. Ching-Yin Lee, Li-Chieh Chen, Shao-Hong Tsai, Wen-Tsan Liu, Yuan-Kang Wu, "The Impact of SCIG Wind Farm Connecting into a Distribution System," Power and Energy Engineering Conference, 2009.
9. Rahmann, H.J. Haubrich, A. Moser, R. Palma-Behnke, L. Vargas, M. B. C. Salles, "Justified Fault-Ride-Through Requirements for Wind Turbines in Power Systems," IEEE Transactions on Power Systems, vol. 26, no. 3, August 2011.
10. Mital G. Kanabar, S. A. Khaparde, "Evaluation of Rotor Speed Stability Margin of a Constant Speed Wind Turbine Generator," Joint International Conference on Power System Technology and IEEE Power India Conference, 2008.
11. Shih-Feng Chou, Chia-Tse Lee, Hsin-Cheng Ko, Po-Tai Cheng, "A Low-Voltage Ride-Through Method with Transformer Flux Compensation Capability of Renew-able Power Grid-Side Converters," 3rd IEEE International Symposium on Power Electronics for Distributed Generation Systems (PEDG), June 2012.
12. Jose Luis Dominguez-Garcia, Oriol GomisBellmunt, Lluís Trilla-Romero, Adria Junyent Ferre, "Vector Control of Squirrel Cage Induction Generator for Wind Power," International Conference on Electrical Machines, 2010.
13. Kyoung-Jun Lee, Dongsul Shin, Dong-Wook Yoo, Hee-Je Kim, "A Novel Grid Synchronization PLL Method Based on Adaptive Low-Pass Notch Filter for Grid-Connected PCS," IEEE Transactions On Industrial Electronics, vol. 61, no. 1, January 2014.
14. Chia-Tse Lee, Che-Wei Hsu, Po-Tai Cheng, "A Low-Voltage Ride-Through Technique for Grid-Connected Converters of Distributed Energy Resources," IEEE Transactions On Industry Applications, vol. 47, no. 4, August 2011.
15. Ki-Hong Kim, Yoon-Cheul Jeung, Dong-Choon Lee, Heung-Geun Kim, "LVRT Scheme of PMSG Wind Power Systems Based on Feedback Linearization," IEEE Transactions On Power Electronics, vol. 27, no. 5, May 2012.
16. Po-Hsu Huang, Mohamed Shawky El Moursi, Weidong Xiao, L. Kirtley Jr., "Novel Fault Ride-Through Configuration and Transient Management Scheme for Doubly Fed Induction Generator," IEEE Transactions On Energy Conversion, vol. 28, no. 1, March 2013.
17. Shuai Xiao, Geng Yang, Honglin Zhou, Hua Geng, "An LVRT Control Strategy Based on Flux Linkage Tracking for DFIG-Based WECS," IEEE Transactions On Industrial Electronics, vol. 60, no. 7, July 2013.
18. Ebrahim Babaei, Mohammad Farhadi Kangarlu, "Cross-phase voltage sag compensator for three-phase distribution systems," International Journal of Electrical Power & Energy Systems, vol. 51, October 2013, pages 119-126.
19. S.M. Mueen, R. Takahashi, T. Murata, J. Tamura, M.H. Ali, Y. Matsumura, A. Kuwayama, T. Matsumoto, "Low voltage ride through capability enhancement of wind turbine generator system during network disturbance," Renewable Power Generation, vol. 3, Issue 1, March 2009.
20. Alvaro Luna, Pedro Rodriguez, Remus Teodorescu, Freede Blaabjerg, "Low Voltage Ride Through Strategies for SCIG Wind Turbines in Distributed Power Generation Systems" Power Electronics Specialists Conference, June 2008.
21. Jaume Miret, Antonio Camacho, Miguel Castilla, Luis Garcia de Vicuna, Jose Matas, "Control Scheme With Voltage Support Capability for Distributed Generation Inverters Under Voltage

- Sags," IEEE Transactions On Power Electronics, vol. 28, no. 11, November 2013.
22. Mohsen Rahimi, Mostafa Parniani, "Coordinated Control Approaches for Low-Voltage Ride-Through Enhancement in Wind Turbines With Doubly Fed Induction Generators," IEEE Transactions On Energy Conversion, vol. 25, no. 3, September 2010.
 23. Manuel Reyes, Pedro Rodriguez, Sergio Vazquez, Alvaro Luna, Remus Teodorescu, Juan Manuel Carrasco, "Enhanced Decoupled Double Synchronous Reference Frame Current Controller for Unbalanced Grid-Voltage Conditions," IEEE Transactions On Power Electronics, vol. 27, no. 9, September 2012
 24. Jose Luis Dominguez-Garcia, Oriol Gomis-Bellmunt, Antoni Sudria-Andreu, Lluís Trilla-Romero, "Indirect Vector Control of an Induction Generator with LVRT capability," Proceedings of the 2011-14th European Conference on Power Electronics and Applications (EPE 2011), August 2011.
 25. Jovica V. Milanovic, Yan Zhang, "Global Minimization of Financial Losses Due to Voltage Sags With FACTS Based Devices," IEEE Transactions On Power Delivery, vol. 25, no. 1, January 2010.
 26. Jovica V. Milanovic, Yan Zhang, "Modeling of FACTS Devices for Voltage Sag Mitigation Studies in Large Power Systems," IEEE Transactions On Power Delivery, vol. 25, no. 4, October 2010.
 27. H. M. Huang, G. W. Chang, C. K. Chen, H. J. Su, T. C. Wu, "A Study of Low Voltage Ride-Through Capability for Offshore Wind Power Plant," IEEE International Conference on Smart Grid Communications, October 2011.
 28. Hailian Xie, Lennart Angquist, Hans-Peter Nee, "Design Study of a Converter Interface Interconnecting Energy Storage With the DC Link of a StatCom" IEEE Transactions On Power Delivery, vol. 26, no. 4, October 2011.
 29. Mojtaba Nemati, Hesam Addin Yousefian, Rouhollah Afshari, "Recognize The Role of a DVR In Power Systems," International Journal of Recent Trends in Engineering, vol 2, no. 7, November 2009.
 30. Naohiro Hasegawa, Teruhisa Kumano, "Low Voltage Ride-Through Capability Improvement of Wind Power Generation Using Dynamic Voltage Restorer," Proceedings of the 5th IASME/WSEAS International Conference on Energy & environment, 2010, Pages 166-171.
 31. Bhim Singh, Jayaprakash P, Kothari D P, Ambrish Chandra, Kamal-Al-Haddad, "Indirect Control of Capacitor Supported DVR for Power Quality Improvement in Distribution System," Power and Energy Society General Meeting Conversion and Delivery of Electrical Energy in the 21st Century, July 2008.
 32. Hyunsik Jo, Ilyong Lee, Byung-Moon Han and Hanju Cha, "A Dynamic Voltage Restorer with a selective Harmonic Mitigation and Robust Peak Detection," Twenty-Eighth Annual IEEE Applied Power Electronics Conference and Exposition (APEC), March, 2013.
 33. H. Gaztafna, I. Etxeberria-Otadui, S. Bacha, D. Roje, "Fixed-Speed Wind Farm Operation Improvement by Using DVR Devices," IEEE International Symposium on Industrial Electronics, June 2007.
 34. N. Amutha, S. Aarthi, B. Kalyan Kumar, "Improving Critical Clearing Time of Grid Connected Squirrel Cage Induction Generator based Wind Generation System using DVR," 11th International Conference on Environment and Electrical Engineering (EEE-IC), May 2012
 35. O. Viktorin, Katholieke Universiteit Leuven, J. Driesen, R. Belmans, "Comparison of dynamic restorer topologies," IEEE Bologna Power Tech Conference Proceedings, vol. 1, June 2003.
 36. Tanonsak Keawsakunee, Paisan Boonchiam, "Detailed Analysis of Control Strategies for Medium Voltage Dynamic Voltage Restorer," 2008.
 37. Christoph Meyer, Christoph Romaus, Rik W. De Doncker, "Optimized Control Strategy for a Medium-Voltage DVR," IEEE Power Electronics Specialists Conference, 2005.
 38. Yan Li, Yun-ling Wang, Bu-han Zhang, Cheng-xiong Mao, "Modeling and Simulation of Dynamic Voltage Restorer Based on Super Capacitor Energy Storage," IEEE Bologna PowerTech Conference, June 2003.
 39. Long Hee Han, Lin Geun Shon, Il Dong Seo, Hee Long Leon, "Development of On-line type Dynamic Voltage Compensation System Using Supercapacitor," International Conference on Power Electronics, October 2007.
 40. R. Omar, N.A. Rahim, "Voltage unbalanced compensation using dynamic voltage restorer based on super capacitor," International Journal of Electrical Power and Energy Systems, vol. 43, Issue 1, December 2012, Pages 573-581.

AUTHORS PROFILE

Radhamani V. Pillay received her Bachelor's degree in Electrical and Electronics Engineering in 1979 from Government Engineering College, Trissur and her Masters de-

gree in Instrumentation and Control System in 1984 from Regional Engineering College, Calicut. She pursued her Ph.d degree on Fault Tolerance and Real time systems in 2013 from Kerala University. On the course of pursuit of research degree, she spent one year in Indian Space Research Organisation (ISRO), Trivandrum and one year in Malardalen University, Sweden. She has 30 years of teaching and research experience and for the past 19 years she has been working in Amrita Viswa Vidhyapeetham University, Coimbatore. Her interests include control systems, fault tolerant real time and embedded systems and sustainable environment management.

Vanitha V. received her B.Tech degree in Electrical and Electronics Engineering from Madurai Kamaraj University in 1992 and M.E. degree in Power Systems from Bharatidasan University in 1993. She pursued her Ph.d degree in Wind Electric Generators in 2012 from Anna University, Chennai.

She has 13 years of teaching experience and she is currently working as an Assistant Professor in Amrita Viswa Vidhyapeetham University, Coimbatore. Her interests include wind electric generators, electrical machines, power quality and power systems.

Anisha Asmy N.R. received her B.E. degree in Electrical and Electronics Engineering from Sri Ramakrishna Engineering College, Coimbatore in 2012 and is currently pursuing her M.Tech degree in Power Electronics from Amrita Viswa Vidhyapeetham University, Coimbatore. Her interests include power converters, power quality and renewable energy.

IJSER