CHECKLIST ANALYSIS OF SEWAGE TREATMENT PLANT IN AN EDUCATIONAL INSTITUITION

G.M.Muhilan¹, T.Dheenathayalan², PSS.Srinivasan³, K.Visagavel⁴, D.Sakthivel⁵

1 PG Scholar, Department of Industrial safety engineering, Knowledge Institute of Technology, Salem, Tamilnadu, India. 2,3,4,5 Faculty of Mechanical Engineering, Knowledge Institute of Technology, Salem, Tamilnadu, India

¹ <u>muhil4u@gmail.com</u> , ² -<u>tdmech@kiot.ac.in</u>

Abstract— Knowledge Institute of Technology Salem is one of the most important Educational institutes in the state of Tamilnadu with a large number of people residing in its campus consisting of a number of laboratories of various departments, residential units and academic blocks. A sewage treatment plant is quite necessary to receive the domestic and commercial waste and removes the materials which pose harm for general public. Its objective is to produce an environmentally-safe fluid waste stream (or treated effluent) and a solid waste (or treated sludge) suitable for disposal or reuse (usually as farm fertilizer). Checklist analysis is a systematic evaluation against pre-established criteria in the form of one or more checklists.

Achievement of a safe and healthful workplace is the responsibility of an organization, the people residing in the place and the workers who are given the charge to protect the environment. Waste disposal and minimization and pollution prevention should be the preferred approach.

Stringent penalties for the improper disposal of wastes should be adopted.

Keywords-checklist analyis; sewage treatment plant; criticality rating; Educational instituition.

INTRODUCTION

Pollution in its broadest sense includes all changes that curtail natural utility and exert deleterious effect on life. The crisis triggered by the rapidly growing population and industrialization with the resultant degradation of the environment causes a grave threat to the quality of life.

Degradation of water quality is the unfavorable alteration of the physical, chemical and biological properties of water that prevents domestic, commercial, industrial, agricultural, recreational and other beneficial uses of water. Sewage and sewage effluents are the major sources of water pollution. Sewage is mainly composed of human fecal material, domestic wastes including wash-water and industrial wastes.

The growing environmental pollution needs for decontaminating waste water result in the study of characterization of waste water, especially domestic sewage. In the past, domestic waste water treatment was mainly confined to organic carbon removal. Recently, increasing pollution in the waste water leads to developing and implementing new treatment techniques to control nitrogen and other priority pollutants

Sewage Treatment Plant is a facility designed to receive the waste from domestic, commercial and industrial sources and to remove materials that damage water quality and compromise public health and safety when discharged into water receiving systems. It includes physical, chemical, and biological processes to remove various contaminants depending on its constituents. Using advanced technology it is now possible to re-use sewage effluent for drinking water. The principal objective of waste water treatment is generally to allow human and industrial effluents to be disposed of without danger to human health or unacceptable damage to the natural environment. An environmentally-safe fluid waste stream is produced. No danger to human health or unacceptable damage to the natural environment is expected.

Sewage includes household waste liquid from toilets, baths, showers, kitchens, sinks and so forth that is disposed of via sewers. Sewage also includes liquid waste from industry and commerce.

TREATMENT PROCESSES:

PRETREATMENT: Large solids (i.e. those with a diameter of more than 2cm) and grit (heavy solids) are removed by screening. These are disposed of in landfills.

PRIMARY TREATMENT: The water is left to stand so that solids can sink to the bottom and oil and grease can rise to the surface. The solids are scraped off the bottom and the scum is washed off with water jets. These two substances are combined to form sludge. A primary sedimentation will remove 50-70 percent total suspended solids and 30-40 percent BODR5R.

SECONDARY TREATMENT: The sludge is further treated in 'sludge digesters': large heated tanks in which its chemical decomposition is catalysed by microorganisms. The sludge is largely converted to 'biogas', a mixture of CH4 and CO2, which is used to generate electricity for the plant.


The liquid is treated by bacteria which break down the organic matter remaining in solution. It is then sent to oxidation ponds where heterotrophic bacteria continue the breakdown of the organics and solar UV light destroys the harmful bacteria.

International Journal of Scientific & Engineering Research, Volume 7, Issue 5, May-2016 ISSN 2229-5518


secondary treatment may remove than 85 percent of the BODR5 Rand suspended solids, it does not remove significant amount of nitrogen, phosphor heavy metals, no degradable organics, bacteria and viruses.

METHODOLOGY:

Procedure for Checklist Analysis:



VULNERABILITYANALYSIS:



ITEMS TO BE IDENTIFIED	CHEO	CKLIST	COMMENTS		
IDENTIFIED	YES	NO			
1. Property is fenc and gated.?	ed				
2. Are all tanks a chambers abo the safe flo- level?	ve				
3. Are there a buried pipelin or cables und buildings with the treatme facility and is clearly indicat on the layo drawings?	ler hin ent it ed				
4. Is the facili located near to public road allow immedia access to t plant/facility?	a to				
5. Adequate signa provided?	ge				
 Location sludge desludgi area is suitable f tankers to acce and empty t 	for				

 studge into the chamber. Have safety handrails or graning been installed at walkways and around open holes at the plant? 8. Is adequate street lighting provided around the plant and what is the number of lamp post provided? 9. Are all buildings and major units at the facility? 10. Where the located is the current facility and is it clearly indicated on the layout drawings with relation for existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the facility? 13. Hence greency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 20. Provision of and pass the influent sewage during power failure (away from residents) and location of power failure (away f	SN 2229	9-5518	a Engineering Res	earch, volume 7, issu	e 5, May-2010	90
 chamber. Have safety handrails or graing been installed at walkways and around per holes at the plant? 8. Is adequately fit and it should be weather proof, argon proof and provided? 9. Are all buildings and what is the mumber of lamp post provided? 9. Are all buildings and excession of claim pipe to drain facility lighted adequately? 10. Where the facility and is it claims of the plant facility indicated on of effluent discharge is point for the facility and is it claims of the plant activities take place, is three provision for stand pipes for clearly indicated on water bodies? 11. If tankers and desludging activities take place, is three provision for stand pipes for cleaning purposes? 12. All a screen of ways for some stand pipes to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from res					force ventilation	
 7. Have safety handralis or graing been installed at walkvays and around open holes at the plant? 8. Is adequate street lighting provided around the plant? 8. Is adequate street lighting provided around the plant? 8. Is adequate street lighting provided? 9. Are all buildings and major units at the reatment facility lighted adequately? 10. Where the location of efficiency with rollers, perforated tray and covers is covering with reatment facility infinited on of efficience to the location of existing receiving water botics? 11. If takers and despite for stand pipes for cleaning purposes? 12. All screen chemication for stand pipes for cleaning purposes? 13. Emergency overflow pipe to bypass the influent sewage during power failure (away from residents) and location of overflow pipe to bypass the influent sewage during power failure (away from residents) and location of overflow pipe to bypass the influent sewage during power failure (away from residents) and location of overflow pipe to bypass the influent sewage during power failure (away from residents) and location of overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of or overflow pipe to bypass the influent sewage during power failure (away from residents) and location of the power failure (away from residents) and location of the power failure (away from residents) and location of the power fail						
 A lave sately handrails or grating been installed at walkways and around open holes at the plant? Is adequate street lighting provided around open holes at the plant? Is adequate street lighting provided around open holes at the plant? Is adequate street lighting provided? A re all buildings at the treatment facility lighted adequately? Where the location of effluent discharge is point for the facility and is it it clearly indicated on the layout drawings with relation to the pump sump to acoustic door? Where the location of existing to the pump sump to acoustic door? It is that street provision for stand pipes for cleaning purposes? All screen chamber sumps to be fully open at the top for good ventilation? Provision of risting street place, is there provision for stand pipes for cleaning for the reatment fighting activities take place, is there provision for stand pipes for cleaning for the reatment the top for good ventilation? Fingenery overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or verflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during the power failure (away from residents) and location of or overflow pipe to by-pass the influent sewage during the power failure (away from residents) and location of the control panels? <		chamber.				
 handrails or graing been installed at walkvays and around open holes at the plan? is adequate street lighting provided around the plant and what is the number of lamp post provided? A re all buildings and what is the increase of lamp post provided? A re all buildings and equately? Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? It is taken and the top for cleaning purpoes? Are all buildings and holes water bodies? It is taken and the top for cleaning purpoes? Are all buildings and holes water bodies? It is taken and the top for good ventilation? Bergency overflow pipe to by for overflow pipe to by pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during the power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during the power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during the power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during the power failure (away from residents) and location of or overflow pipe to by pass the influent sewage during the power failure (away from residents) and location of the control panels? It is the or wall be the pass of the pass	7.	Have safety				
graing been installed at walkways and around open holes it 8. Is adequate street it lighting provided around the plant and what is the number of lamp post provided? covers 9. Are all buildings and major units at the freatment facility in the facility and is it covers calearly indicated oor on the layout acoustic activities take pace incluster place, is there provision of relating pace 10. Where the provision of location of coversion of relating with pace, is in the relating with pace, is the place, is there provision of relating pace, is there provision for for stand pipes for cleaning purposes? 10. Fass and 12. All screen for relaming power pace, is there provision of						
 installed at workways and around open holes at the plant? 15. Dry well adequately lit and it should be weather proof. A sport proof and provision of grit storage bin or skip work weather proof. A provision of grit storage bin or skip perforated tray and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relations to the grit removal facility? 11. If tankers and desline to the provision of acoustic door? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to bypass the influent sewage during power failure (away from residents) and location of overflow pipe to bypass the installation during maintenance? 14. If tankers and docation of overflow pipe to bypass the installation during maintenance? 15. Dry well addition and board of overflow pipe to bypass the installation during maintenance? 16. Face wall 17. Provision of acoustic door? 18. Provision of acoustic door? 19. Provision of exhaust fan with the top for good ventilation? 10. Where the control panels? 11. If tankers and discharge is the provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to bypass the installation during maintenance? 24. Water storage task to be located in such away that way that way that water will not be control panels? 						
 walkways and around open holes at the plant? 8. Is adequate street lighting provided around the plant and what is the number of lamp post provided? 9. Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of efficient discharge is point for the facility indicated on the layout drawings with relation to relations take place, is there provision for stand pipes for cleaning purposes? 12. All screen channels and pipes for cleaning purposes? 13. Emergency overflow pipe to the fully open at the top for good venitilation? 14. If tankers and discharge grows the influent sewage the top for good venitilation? 15. Dry well addition and location of course for plant and what is the top for good venitilation? 14. If the top for good venitilation? 15. Dry well addition? 16. Easy access to the grit removal facility? 17. Provision of arian water into the pump sump to avoid ponding? 18. Provision of acoustic door? 19. Provision of rotating strobe light at the control room to indicate malfunction of blower rooms? 20. Provision of adequate space for blower room and room to indicate malfunction of blower room and room to indicate malfunction of blower removal or installation during maintenance? 20. Water storage tank to be located in such awy that water will not be control panels? 		0 0			cooling?	
 around open holes at the plant? adequate street lighting provided around the plant and what is the number of lamp post provided? Are all buildings and major units at the treatment facility? lighted adequately? Mhere the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? If tankers and desludging activities take place, is three purposes? All screen chamber sumps to be fully open at the tog and purposes? All screen chamber sumps to by pass the influent sewage during power failure? In greating purposes? It functs and docation of overthow pipe to discharge? Market song the facility open at the tog and adocation of overthow pipe to by pass the influent sewage during power failure? It for a for any purposes? All screen chamber sumps to bower including and location of overthow pipe to by pass the influent sewage during power failure? All screen chamber sumps to bower removal or installation during maintenance? All screen chamber for blower removal or installation during maintenance? All screen chamber for prody wentilation? Intergency overthow pipe to by pass the influent sewage during power failure (avay from residents) and location of overthow pipe to blower removal or installation during maintenance? It for for a for particulate air around the location of overthow pipe to blower removal or installation during maintenance? It for for a for particulate air around the location of overthow pipe to blower removal or installation during maintenance? It for for a sub on the control panels? 					15 Dev wall	
at the plan? ii should be 8. Is adequate street ighting provided and what is the weather proof, number of lamp post provided? 9. Are all buildings and major units at the treatment facility lighted adequately? 16. Easy access to the git is point for the facility of is it clearly indicated or on the layout activities take packs, is three provision of actain vater bodies? is Provision of actain 11. If tankers and desludging activities take pace, is three pace, is three provision of realing purposes? 12. All screen chains chains exampt provision of and location of genere overflow pipe to provision of packing power failure (away find targe power failure (away from residents and location of overflow pipe to provision of phore power and location of desinglarge 20. Provisi						
 8. Is adequate street lighting provided around the plant and what is the number of lamp post provided? 9. Are all buildings and major units at the treatment facility? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to builty open at the toget of by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to by-pass the installation doring maintenance? 14. Ke for watel 						
 as adequate street lighting provided? Are all buildings and major units at the treatment facility lighted adequately? Where the hostin of the facility and is it clearly indicated on the layout drawings with relation to cexisting receiving water bodies? If a markers and desleging provision of receives for blowers including accoustic door? If a markers and the state place, is there provision for cleaning purposes? Render and provision of addition of overflow pipe to brain with silencer to installation during influent sewage during power failure (away from residents) and location of overflow pipe to brain system the facting? Where the place is there provision for the factor of the factor o		at the plant?				
lighting provided around the plant and what is the number of lamp post provided? 9. Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility indicated on the layout dawings with relation to cexisting receiving water bodies? 11. If tankers and place, is there provision for stand pipes relation? 12. All screen chamber sumps to bypass the influent sewage during power failuo per solution overflow pipe to bypass the influent sewage during power failure (away) failure (away) failure (away) failure (away) failure (away) failure (away) <td>8</td> <td>Is adaquata streat</td> <td></td> <td></td> <td></td> <td></td>	8	Is adaquata streat				
around the plant and what is the mumber of lamp post provided? 9. Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to byspass the the top for good ventilation? 14. Is drea wall discharge? 15. Emergency overflow pipe to byspass the discharge? 16. Easy access to the grit removal activities take place, is there provision for stand pipes for cleaning purposes? 17. Provision of activities take chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to byspass the installation drain from residents) and location of overflow pipe to byspass the discharge?	0.					
 and what is the number of lamp post provided? 9. Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of efficient discharge is point for the facility and is it clearly indicated on the layout drawings with relation to to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the fordity open at the fully open at the facility open at the fully open at t					Provision of grit	
 and what is the number of lamp post provided? Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If trankers and destudging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 21. Provision of action of by provision of rots in dicate malfunction of by proses the top for good ventilation? 22. Water storage tank to be located of action of overflow pipe to by proses the top for good ventilation? 23. All screen chamber sumps to be fully open at the top for good ventilation? 24. Is careen chamber sumps to bowers indicate malfunction of blower removal or installation during maintenance? 24. Is draway from residents) and location of overflow pipe to by proses the top for good ventilation? 24. Is draway from residents) and location of overflow pipe to by proses the biower storage tank to be located to in such a way that water will not way that water will not splash on the control panels? 					storage bin or skip	
 number of r lamp post provided? 9. Are all buildings and major units at the irreatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for clearing purposes? 12. All screen chamber sumps to the for the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to draw and by-pass the installation during maintenance? 14. Is draw awall 						
90 Are all buildings and major units at the treatment facility lighted adequately? iand covers? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 17. Provision of drain pipe to drain water into the pump sump to acoustic enclosures for blowers including accustic door? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 18. Provision of acoustic door? 12. All screen chamber sumps to be fully open at the top for good ventilation? 20. Provision of rotating strobe light at the control blower removal or installation during purposes? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of rotating strobe light at the control blower removal or installation during maintenance? 21. Vater storage tank to be located in such away that water will not vertilw pipe 22. Water storage tank to be located in such away that water will no the control panels?						
 9. Are all buildings and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the the top for good ventilation? 14. Is dry awall 15. Emergency 16. Easy access to the grit receivants 16. Easy access to the grit removal failure (away from residents) and location of overflow pipe 14. Is dry awall 15. Emergency 16. Easy access to the grit removal failure (away from residents) 16. Easy access to the grit removal failure (away from the sevage dry and the blow 17. Provision of accounts 18. Provision of accounts 19. Provision of control failer 10. Provision of control failer 11. If tankers and discharge? 12. All screen chamber sumps to be failly open at the top for good 13. Emergency overflow pipe to by-pass the failure (away from residents) 14. Is dry awall 15. Emergency 16. Easy access the screen accounts 17. Provision of adequate space for blower removal failer 18. Provision of adequate space for blower accounts 19. Provision of adequate space for blower accounts 10. Emergency 11. If the top for good 12. All screen chamber sumps to the the top for good 13. Emergency 14. Is dry awall 14. Is dry aw		post provided?				
 and major units at the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desting receiving activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to during power discharge? 14. Is dry wall 	0	Ana all haddanaa				
 the treatment facility lighted adequately? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desting receiving purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to brypas the influent sewage during power failure (away frime (away fri	9.				explosion proof.	
nee treatment facility lighted adequately? it 10. Where the blocation of effluent discharge it is point for the facility? facility: avoid ponding? clearly indicated acoustic on the layout drawings with relation to vater bodies? 19. Provision 11. If tankers and acoustic activities take place, is there purposes? 20. Provision stand pize, so purposes? 20. Provision of rotating purposes? 12. All screen chamber sumps to bower or other be fully open at the top for good ventilation? 21. Provision of overflow pipe to bower strobe bower removal or installation during influent sewage tank to be located during power failue adequate space for		-			16. Easy access to the	
facility facility? 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 17. Provision of drain pipe to drain water into the pump sump to acoustic door? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 18. Provision of acoustic door? 12. All screen chamber sumps to be fully open at the top for good ventilation? 20. Provision of rotating strobe light at the control room to indicate malfunction of bolower or other equipment? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 14. Is dry, wall 4. Is dry, wall 21. Is dry, wall						
 adequately? 10. Where the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is dry, will 14. Is dry, will 14. Is dry, will 14. Is dry, will 15. Emergency 16. Emergency 17. Provision of drain pipe to drain water will not system. 18. Provision of exhaust fan with silencer to circulate air around the blower roow? 19. Provision of rotating strobe light at the control problem of the layout water will not system. 19. Provision of an an around the blower removal or installation during maintenance? 19. Provision of a swy that water will not system. 11. If tankers ways the influent sewage takes the provision of the control panels? 						
 10. Where the location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 14. Is dry, wall 		adequately?				
 location of effluent discharge is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the to for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is dry wall 15. Is dry wall 16. Is dry wall 16. Is dry wall 16. Is dry wall 17. Is dry wall 18. Provision of activities at the control room is stand pipes for cleaning the provision of the provision of the provision of the promote the provision of the control room to indicate malfunction of the provision of the pr	10	Where the				
 effluent discharge is point for the facility and is i clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumpt to avoid ponding? 13. Breargency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe 14. Is dry wall 14. Is dry wall 14. Is dry wall 15. Water influent sewage during power failure (away from residents) and location of overflow pipe 14. Is dry wall 14. Is dry wall 15. The dry wall 16. The dry wall 17. The dry wall 18. Provision of acoustic door? 19. Provision of creating strobe light at the control room to indicate malfunction of bolower removal or installation during maintenance? 14. Is dry wall 14. Is dry wall 15. The dry wall 16. The dry wall 17. The dry wall 18. Provision of accoustic door? 19. Provision of rotating strobe light at the control room to indicate malfunction of overflow pipe 10. The dry wall 11. If tankers and discharge? 12. All screen charber and the dow wall 13. The dry wall 14. Is dry wall 14. Is dry wall 14. Is dry wall 14. Is dry wall 15. The dry wall 16. The dry wall 17. The dry wall 18. Provision of accust of dry dry dry dry dry dry dry dry dry dry	10.				pipe to drain	
 is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is draw wall 					water into the	
 is point for the facility and is it clearly indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is dry, wall 					pump sump to	
 14 Lifty indicated on the layout drawings with relation to existing receiving water bodies? 11. If tankers and desludging acoustic door? 19. Provision of exhaust fan with silencer to circulate air around the blower room? 10. Provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away) from residents) and location of overflow pipe discharge? 14. Is dry, well 					avoid ponding?	
on the layout drawings with relation to to enclosures for blowers including acoustic door? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is dry, wall						
drawings with relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 19. Provision of exhaust fan with silencer to circulate air around the blower room? 12. All screen chamber sumps to be fully open at the top for good ventilation? 20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 14 Is dry, wall 4 a b dry, wall						
relation to existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge?						
 existing receiving water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to overflow pipe to isolation during maintenance? 14. Is drv well 						
 water bodies? 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 14. Is dry, well 					blowers including	
11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 19. Provision of exhaust fan with silencer to circulate air around the blower room? 12. All screen chamber sumps to be fully open at the top for good ventilation? 20. Provision of room to indicate malfunction of blower or other equipment? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe to discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 14. Is draw wall 14. Is draw wall 14. Is draw wall		existing receiving			acoustic door?	
 11. If tankers and desludging activities take place, is there provision for stand pipes for cleaning purposes? 12. All screen chamber sumps to be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of owerflow pipe discharge? 14. Is dry, well 		water bodies?			10 Decision of	
desludging activities take place, is there provision for stand pipes for cleaning purposes?silencer circulateto air around the blower room?12. All chamber sumps to be fully open at the top for good ventilation?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?13. Emergency overflow pipe to by-pass during rom residents) and location of overflow pipe discharge?21. Provision of adequate space for blower removal or installation during maintenance?14. Is often were control panels?14. Is often were room	1.1					
activitiestake place, iscirculateair around the blower room?stand pipes for cleaning purposes?20. Provisionof rotating12. All chamber sumps to be fully open at the top for good ventilation?20. Provisionof rotating13. Emergency overflow pipe to by-pass21. Provisionof adequate space for blower removal or installation during maintenance?13. Emergency overflow pipe to by-pass21. Provisionof adequate space for blower removal or installation during maintenance?14. Is dvdway proverflow pipe22. Water storage tank to be located in such a way that water will not splashon the control panels?	11.					
place, is there provisionaround the blower room?stand pipes for cleaning purposes?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?12. All chamber sumps to be fully open at the top for good ventilation?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe21. Provision of adequate space for blower removal or installation during maintenance?14. Is drydrywell						
provisionfor stand pipesroom?stand pipesfor cleaning purposes?20. Provisionof rotating strobe light at the control room to indicate malfunction12. Allscreen chamber sumps to be fully open at the top for good ventilation?20. Provision room to indicate malfunction13. Emergency overflow pipe to by-pass21. Provision of adequate space for blower removal or installation during maintenance?22. Waterstorage tank to be located in such a way that water water will not splash on the control panels?						
stand pipes for cleaning purposes?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?12. All screen chamber sumps to be fully open at the top for good ventilation?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge?21. Provision of adequate space for blower removal or installation during maintenance?22. Water storage tank to be located in such a way that water will not splash on the control panels?		1 .				
cleaning purposes?20. Provision of rotating strobe light at the control room to indicate malfunction of blower or other equipment?12. All screen chamber sumps to be fully open at the top for good ventilation?12. All screen chamber sumps to be fully open at the top for good ventilation?13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge?21. Provision of adequate space for blower removal or installation during maintenance?22. Water storage tank to be located in such a way that water will not splash on the control panels?		provision for			room?	
cleaning purposes?rotating strobe light at the control room to indicate malfunction of blower or other equipment?12. All screen chamber sumps to be fully open at the top for good ventilation?rotating strobe light at the control room to indicate malfunction of blower or other equipment?13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge?21. Provision of adequate space for blower removal or installation during maintenance?22. Water storage tank to be located in such a way that water will not splash on the control panels?		stand pipes for			20 Duravision of	
12. All screen chamber sumps to be fully open at the top for good ventilation? light at the control room to indicate malfunction of blower or other equipment? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 14. Is dry well 14. Is dry well		cleaning				
12. All screen chamber sumps to be fully open at the top for good ventilation? room to indicate malfunction of blower or other equipment? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 14. Is dry well 4. Is dry well						
chamber sumps to be fully open at the top for good ventilation? malfunction of blower or other equipment? 13. Emergency overflow pipe to by-pass influent sewage during power failure (away from residents) and location of overflow pipe discharge? 21. Provision of adequate space for blower removal or installation during maintenance? 22. Water storage tank to be located in such a way that water will not splash on the control panels?						
be fully open at the top for good ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 14. Is dry well	12.					
the top for good ventilation?equipment?13. Emergency overflow pipe to by-pass21. Provision of adequate space for blower removal or installation during maintenance?22. Water failure during power failure (away from residents) and location of overflow pipe discharge?22. Water storage tank to be located in such a way that water will not splash on the control panels?						
ventilation? 13. Emergency overflow pipe to by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 14. Is dry well		be fully open at				
13. Emergency overflow pipe to by-pass 21. Provision of adequate space for blower removal or installation during maintenance? 14. Is dry well					equipment?	
13. Emergency overflow pipe to by-pass adequate space for blower removal or installation during maintenance? 22. Water storage tank to be located in such a way that water will not splash on the control panels?		ventilation?			21 Provision of	
overflow pipe to blower removal or by-pass the influent sewage during power failure (away from residents) and location of overflow pipe discharge? 14 Is dty well	10					
by-pass the installation during maintenance? during power failure (away from residents) and location of overflow pipe discharge? 14 Is dry well	13.					
influent sewage during power failure (away from residents) and location of overflow pipe discharge? 14 Is dry well						
during power failure (away from residents) and location of overflow pipe discharge?						
failure (away from residents) and location of overflow pipe discharge? 14 Is dry well		Ũ			maintenance?	
failure (away from residents) and location of overflow pipe discharge? 14 Is dry well		during power			22 Weter stores	
from residents) and location of overflow pipe discharge? 14 Is dry well		e 1			Ũ	
and location of overflow pipe discharge?						
overflow pipe discharge? water will not splash on the control panels?		,				
discharge? splash on the control panels?						
14 Is dry well						
14 Is dry well		-			control panels?	
	14.				23. Provision of	
provided with		provided with				

ISSN 2229-5518	
potable/clean	
water for regular	
cleaning of the	
overflow weir	
Provision of force	
main type of pipe	
from the thickener	
to the sludge	
holding tank?	
24. Each sludge	
holding tank to	
have separate	
feeding pipes with	
individual	
isolating valves?	
25. Is the safety	
provisions	
adequate?	

 Table
 General standards for Discharge of Environmental Pollutants, Part A: Effluents as per Schedule VI of the Environmental (Protection) Rules 1986 and National River Conservation Directorate Guidelines for Faecal Coliforms, (Values in mg/l unless stated)

	Characteristics	Standards				
No		Inland Surface Water	Public Sewers, (A)	Land for Irrigation	Marine Coastal Areas	
1	Colour and odour	(B)		(B)	(B)	
2	SS	100	600	200	(C), (D)	
3	Particle size of SS	(E)	-	-	(F), (G)	
4	pH value		5.5 to	9.0		
5	Temperature	(H)			(H)	
6	Oil and grease	10	20	10	10	
7	Total residual chlorine	1.0			1.0	
8	Ammoniacal nitrogen (as N)	50	50	-	50	
9	Total Kjeldahl Nitrogen, (TKN) (as N)	100		•	100	
10	Free ammonia (as NH ₃)	5.0		-	5.0	
11	Biochemical Oxygen Demand	30	350	100	100	
12	Chemical Oxygen Demand	250	-		250	
13	Arsenic (as As)	0.2				
14	Mercury (as Hg)	0.01	0.01	-	0.01	
15	Lead (as Pb)	0.1	1.0	-	2.0	
16	Cadmium (as Cd)	2.0	1.0	-	2.0	
17	Hexavalent Chromium (as Cr 6+)	0.1	2.0	-	1.0	
18	Total Chromium (as Cr)	2.0	2.0		2.0	
19	Copper (as Cu)	3.0	3.0		3.0	
20	Zinc (as Zn)	5.0	15.0	720	15.0	
21	Selenium (as Se)	0.05	0.05	•	0.05	
22	Nickel (as Ni)	3.0	3.0	-	5.0	
23	Cyanide (as CN)	0.2	2.0	0.2	0.2	
24	Fluoride (as F)	2.0	15.0	-	15.0	
25	Dissolved phosphates (as P)	5.0	-	-	-	
26	Sulphide (as S)	2.0	-	-	5.0	

Table General Treatment Efficiencies of Conventional Treatment Processes

		Per	Percentage Reduction			
	Process	SS	BOD	Total Coliform		
1	Primary treatment (sedimentation)	45-60	30-45	40-60		
2	Secondary treatment					
	(i) Activated sludge plants	85-90	85-95	90-96		
	(ii) Stabilisation ponds (single cell)	80-90	90-95	90-95		
	(iii) Stabilization ponds (two cells)	90-95	95-97	95-98		

RECOMMENDATIONS & CONCLUSION

This study will be helpful for identifying the significant environmental aspect that causes an adverse effect on the environment. This assessment process document becomes a reference for understanding the standards of an HSE programs evolution-process and for future assessments.

The pH value lies between the permissible limit.

The solid wastes from kitchen is used as animal feeds which can be treated with saw dust and dried can be used as fertilizers.

REFERENCES

- [1] AMERICAN HEALTH ASSOCIATION, 1985 : STANDARD METHODS FOR THE EXAMINATION OF WATER & WASTE WATER -(16th edition)
- [2] ORHON,D. ATES. E., SOZEN. S., 1997 : CHARACTERIZATION AND COD FRACTIONATION OF DOMESTIC WASTE WATER, ENVIRONMENTAL POLLUTION 95(2), 191 – 204
- [3] GERARD KIELY, 2007 , ENVIRONMENTAL ENGINEERING
- [4] KHANNA PUBLISHER, GARG S.K. , 1976 : ENVIRONMENTAL ENGINEERING - (2010 EDITION)
- [5] S. I. KHAN AND N. KAMAL: ASSESSMENT OF TREATMENT EFFICIENCY BY QUANTITATIVE RECOVERY OF INDICATOR BACTERIAAND PATHOGENS IN SEWAGE EFFLUENTS. 129. DEPARTMENT OF MICROBIOLOGY, UNIVERSITY OF DHAKA, BANGLADESH.
- [6] IS:10500 DRAFT INDIAN STANDARD DRINKING WATER –SPECIFICATION (Second Revision of IS 10500)
- [7] DUGAN, P.R. (1972). BIOCHEMICAL ECOLOGY OF WATER POLLUTION. PLENUM PRESS LONDON, 159.
- [8] ENVIRONMENTAL (PROTECTION)RULES 1986.

IJSER