

Coolant Flow Measurement at Different Core flow Conditions in PHWR Nuclear Power Plants

Vinod Nayak^a, A.M.Shaikh^b, Anand Kamat^a

Abstract— Flow distribution in the channels is the basic requirement for the removal of heat from the core effectively and evenly. The channel flow calculation at various gross core flow conditions is a challenging task for the nuclear core of Pressurized Heavy Water Reactor (PHWR). Individual channel flow is necessary for calculating the coasting down pattern of the flow during slow reduction of gross flow after loss of power to the circulating pumps. Individual Channel Flow is also important to predict the flow through different channels of the reactor at various conditions of the core. The various conditions may be the different combination of main pump operation or shutdown pump operation or different header pressure conditions or at various reactor power states. The flow through each channel is critical as it has to remove the heat from fuel. This flow is proportional to the thermal power produced by each channel. Since measurement of flow using instruments in all the channels is not feasible due to its complexity and economic considerations.

An algorithmic approach is modeled for simulating the flow at various header pressure conditions which will change at various operating as well as at different shut down (S/D) conditions. The design flow is matched with the calculated flow considering the various losses due to the flow barriers at normal operating conditions. The flow is simulated at different operating and at various core flow states by changing the inlet (I/L) header and outlet (O/L) header pressures. An algorithm is presented to compute the flow at various header I/L and O/L pressures.

Index Terms— “Flow algorithm, Core flow conditions, PHWR, Pressure difference, Channel flow, Flow Model, Design Flow”. —

1 INTRODUCTION

Coolant in a nuclear power plant plays an important role to transport the primary heat from the core to secondary system to have the effective power generation. The pattern of flow distribution is decided based on the channel power which is a function of the fuel burn up ratio. In the matrix of coolant channels the central channels have more burn up ratio necessitating the maximum flow and the outer channels having less fuel burn up ratio demands less flow compared to inner channels.

The Primary Coolant Pumps which cater this flow through the North and South header systems to the entire channel matrix. The system of feeders through which the flow is distributed in the channels is undergoing various losses due to the bends restrictions and various constrained path due to fuel and other seal and shield plugs.

The flow through each channel is important as it has to remove the heat from fuel and this flow is proportional to the thermal power produced by each channel. Since measurement of flow using instruments in all the channels is not feasible due to its complexity and economic considerations. Therefore, an algorithmic approach is modeled for simulating the flow at various header pressure conditions which will change at various operating as well as at different Shut Down conditions.

- Vinod Nayak is currently pursuing Phd program in Computer science from Shivaji University Kolhapur Mob-9480474242. E-mail: vinodsvs1@gmail.com
- A.M.Shaikh is currently working as prof. Department of Electronics, The New College, Kolhapur- 416 012 MS, India
- Anand Kamat is currently working in Nuclear Power Corporation of India, Kaiga Plant, Karwar, Karnataka, India.

2.0 PHT SYSTEM

The Primary Heat Transport (PHT) System, main circuit, provides the means for transferring heat produced in the

fuel to feed the water in steam generator (SG) in which steam is generated to run the turbine. The heat transport medium is pressurized by heavy water and is circulated through the main circuit by primary circulating pumps (PCPs). Bi-directional fueling adopted for uniform neutron flux necessitates opposite bi-directional flow in adjacent channels. This has been accomplished by a series-parallel arrangement which has lower hold-up, lower piping cost and lower hydraulic losses as compared to parallel arrangement. The Nuclear Power Plants such as Kaiga plant which use valve-less system design for PHT main circuit, eliminate SG-PCP isolation valves. This system has the following advantages.

- a) Availability of thermosyphoning as a passive mode.
- b) Reduction of Radiation dose Intake for valve maintenance.
- c) Reduction of potential heavy water leak points.

2.1 Main Circuit




Fig-1 Primary Heat Transport System main circuit.

Fig-1 shows the main circuit of Primary Heat Transport System. The heavy water runs from inlet headers to inlet feeders into 306 coolant tubes, through the end fittings to outlet feeders and to the reactor outlet headers. The reactor utilizes restriction orifices

in selected inlet feeders to achieve the required flow by the reactor channel ratings, to maintain equal outlet temperatures from all the channels. At full power, the temperature difference (ΔT) between I/L and O/L across each channel is 44.4°C. The reactor outlet headers distribute the flow to the respective steam generator. From the steam generator the heavy water arrives at the primary circulating pumps. There are four steam generators and four primary circulating pumps. Each pump is associated with its steam generator. The pumps discharge the flow into the reactor inlet headers. No common suction header has been provided and pumps are connected directly to the steam generators. From the reactor inlet headers the heavy water flows through the feeders and end fittings to the reactor coolant tubes.

In the PHWR having valve less system, flow path is always available to have continuous circulation through the core at all the times. Power extraction under possible modes of operation is as follows.

I. 2-2 Mode: All four PCPs operate extracting 100% reactor power. This is the normal mode of operation.

II. 1-1 Mode: One pump on each bank operates. Maximum 50% of reactor power can be extracted (assuming ΔT of 44.4°C). However setback is provided till 2% of Full Power.

III. 2-0/0-2/1-0/0-1 Mode: Absolute trip Thermo wells and Resistance Temperature Detector (RTD) inserts have been provided at inlet and outlet of each SG (heavy water side) to measure ΔT across SG. Provision also exists to measure ΔT of 8 selected channels (where flow is being measured) for the purpose of reactor power calculation.

2.2 DESIGN PARAMETERS FOR MAIN SYSTEM:

Design pressure - 112.5 kg/cm²
 Design temperature - 300 °C
 Material - Carbon Steel
 Design pressure for coolant channels (Zr-2.5% Nb) at various temperatures is given below

250 °C = 111 kg/cm² (g)
 262 °C = 109 kg/cm² (g)
 300 °C = 104 kg/cm² (g).

2.3 EMERGENCY CORE COOLING SYSTEM:

In the event of a leak from the primary system, cooling of the fuel can be maintained by the emergency core cooling system. The system injects heavy water from the heavy water accumulators when the PHT pressure at reactor inlet headers falls to 55 Kg/cm². If the pressure continues to fall at 32 Kg/cm² (along with conditioning signals) light water injection is initiated from light water accumulators. Further cooling is resorted by recirculation of water from and to the suppression pool by means of pumps. Decay heat in this condition is removed by plate type heat exchangers.

2.4 SHUT DOWN COOLING SYSTEM:

For cooling the system below 150°C and for holding the system at low temperature during plant maintenance an auxiliary cooling system is provided which is called as shutdown cooling system. The system is connected between the reactor outlet and inlet header at west side on both the banks. The S/D system is also meant for providing header level control, for maintenance of S/D circuit valves, ECCS valves, Instrumented Relief

Valves (IRV), feed check valves and ISI / maintenance on SGs and PCPs [1].

3.0 DESCRIPTION OF THE SYSTEM

3.1 PURPOSE OF THE SYSTEM

Low flow will result in temperature rise in the fuel channel which may lead to fuel failure if the channel is left unmonitored [2]. The detection of low flow can be achieved by one of the two methods. (1) Directly by measurement of channel flow. (2) Indirectly by measurement of channel outlet temperature or indirectly by varying pressure difference in the system.

While deciding the type of measurement, emphasis was given to have minimum number of welded joints, less number of tubes, instruments, mechanical joints, instruments to tube joints etc. so that chances of leakages are reduced as the system carries heavy water at high pressure and high temperature with the radioactivity present in the fluid.

3.2 DESIGN BASIS

The number of channels and their locations which employ channel flow measurement are decided on the following consideration [2].

- (1) The channel thus selected should represent all zones i.e. at least one channel shall be selected from each zone.
- (2) Equal number of channels is selected from north and South zone.

4.0 DESIGN CONSIDERATION

GENERAL

The channel flow measurement is a safety related system. The design of channel flow instrumentation and control system calls for consideration of following criteria as stipulated in IAEA safety guides SG-D8 [3].

- 1) Single failure criteria
- 2) Fail safe design
- 3) Criteria of independence
- 4) Reliability
- 5) Diversity

The above criteria are adhered to our design in following ways:

- a) Triplexation instruments/instrument loops and using two out of three voting mode for actuation of final equipment.
- b) Using fail safe philosophy for all alarm actuating device and relays used for actuation of logic [2].




Fig-2 Zonal Representation for representative Channel flow measurement

5.0 CHANNEL FLOW FOR DIFFERENT HEADER PRESSURES




Fig-4 Ray diagram of Primary Heat Transport System

Fig-4 shows the coolant flow path in Primary Heat Transport System. The thermal rating of the 306 fuel channels varies according to the flux pattern with a maximum to minimum ratio of approximately 2.4. It is necessary to match the coolant flow to the heat generated in each channel to minimize the variation in outlet coolant temperature. Uniformity in coolant conditions is essential as these are basic parameters in the channel structural design and in the plant thermal cycle. The flow resistance of feeders is designed to provide an appropriate flow of coolant to each channel at rated difference in circulating head between the reactor headers. The hydraulic analysis takes account of the channel flow losses which include an orifice element mounted on the end fitting shield plug and also an Inconel restriction orifice in some of the inlet feeders [4]. These channels are classified into 153 North Upstream channels fed from NRIH to SROH and 153 South Upstream channels fed from SRIH to NROH. The overall flow control is done as per the design flow pattern through the feeder and the total PCP flow is matched with total out coming flow through the reactor. This balances the actual flow with channel flow [4].




Fig-3 Flow calculation Algorithm

The Pattern of Feeder arrangement at the reactor core can be broadly classified into 4 cases.

Case-1 Feeders with single diameter at the I/L and O/L without orifice.

Case-2 Feeders with single diameter at the I/L and O/L with orifice.

Case-3 Feeders with Two diameters at the I/L and O/L without orifice.

Case-4 Feeders with Two diameters at the I/L and O/L with orifice.

The Coolant through the reactor core passes through the system of feeders arranged at Inlet and Outlet. The Head loss of the coolant is measured in the following manner [5].

1. Head Loss due to I/L feeder
2. Head loss due to I/L feeder with 900 bends.
3. Head loss due to Fuel path.
(This Loss is the combination of End Fittings, Fuel path Loss and the Shield plugs loss)
4. Head Loss due to O/L feeder.
5. Head Loss due to O/L feeder with 900 bends.
6. Head loss due to orifice at peripheral channels as a flow balancing restriction.

The Design flow is converted into velocity at the Inlet and the velocity at the outlet is calculated by considering the losses [5].

Case-1 Procedure for calculation of losses in feeders of single diameter without orifice [5, 6].

Channel No: North/South Design flow Q in Kg/hr

INLET FEEDER

Inlet feeder diameter D in mm = D in m
Inlet feeder Length L in mm = L in m
No. of bends in inlet feeder N

OUT LET FEEDER

Outlet feeder diameter d in mm = d in m
Outlet feeder length l in mm = l in m
No. of bends in outlet feeder n1

Since D=d because of single diameter feeders

Total feeder length L=L+l in m

Area of inlet feeder A1=πD²/4

Q=A1V1 Q'=(Q/3600*885.4) m³/s where Q = flow

Velocity at the inlet V1=Q*4/πD² m/s

γ = viscosity = 0.01*10⁻⁴ = 10⁻⁶ Pa-s

Re=(V D1/ γ) = V D/10⁻⁶ where Re is Raynolds number

Co-efficient of friction f=0.0008+ (0.05525/ (Re)^{0.237}

FRICION LOSS IN FEEDER OF DIAMETER D

$h_f (D) = 4 f * L * V_1^2 / 2 * g * D \quad (i)$

INLET LOSSES

$I_1 = h_i + h_o + h_B \quad \text{Feeder inlet loss} \quad (ii)$

$h_i = (0.5 V_1^2) / 2g$ Head loss when water enters the feeder from header

Feeder exit or outlet loss

$h_o = (V_1^2) / 2g$ Head loss when water exit the feeder D

Feeder bend loss

$h_B = [(0.1 V_1^2) / 2g] * N_1$

OUTLET LOSSES

$O_1 = h_i + h_o + h_b \quad (iii)$

Feeder inlet loss

$h_i = (0.5 V_1^2) / 2g$ Head loss when water enters the feeder from channel

Feeder exit or outlet loss

$h_o = (V_1^2) / 2g$ Head loss when water exit the feeder d

Feeder bend loss

$$h_b = [(0.1 V12)/2g]*n1$$

HEAD LOSS IN FUEL PATH [7]

Diameter of fuel bundles pencils $d=15.21\text{mm} = 0.01521\text{m}$

$$A_d = \pi d^2/4$$

Diameter of fuel bundles $D=82.50\text{mm} = 0.0825\text{m}$

$$A_D = \pi D^2/4$$

Length of the fuel column $L=6000\text{mm} = 6\text{m}$

Area for water flow (AD-Ad) $A_f = 0.00192\text{m}^2$

$$h_f (\text{fuel}) = [f/2(\pi d^{19} + \pi D)^2 L^3 V^3] / A_f * g \quad (\text{iv})$$

$$A1V1 = A_f V^3$$

$$V^3 = A1V1 / A_f$$

HEAD LOSS IN SHIELD PLUGS [8]

$H_{sp} = [\text{Inlet Bend Loss (a)} + h_f (\text{b}) + \text{Loss in holes (c)} + \text{Outlet Bend Loss (d)}] * 2 \quad (\text{v})$

$$\text{Inlet Bend Loss} = (0.1 V12)/2g \quad (\text{a})$$

Outer diameter of liner tube $d=90.6\text{mm} = 0.0906\text{m}$

$$a_{sp} = \pi d^2/4 \quad \text{m}^2$$

Inner diameter of end fitting $D=107.57\text{mm} = 0.10757\text{m}$

$$A_{sp} = \pi D^2/4 \quad \text{m}^2$$

Length of liner tube $L_s = 1850\text{mm} = 1.85\text{m}$

Area for water flow $A_{sd} = A_{sp} - a_{sp} \quad \text{m}^2$

$$A1V1 = A_{sp} V^4$$

$$h_{f1} = [f/2(\pi d + \pi D)^2 L_s^3 V^4] / A_{sd} * g \quad (\text{b})$$

Note: $V^4 = A1V1$

Diameter of holes in the shield plug $d_h = \text{ø of hole} = 12.7\text{mm} = 0.0127\text{m}$

$$A_h = \pi d_h^2/4 \quad A1V1 = A_h V_h \quad V_h = A1V1 / A_h$$

V_h - Velocity of water passing through hole

Velocity at vena Contracta $V_c = V_h / 0.62$

$$\text{Loss in holes} = [(V_c - V_h)^2 / 2g] * 52 \quad (\text{c})$$

$$\text{Outlet Bend Loss} = (0.1 V32)/2g \quad (\text{d})$$

Note: $A1V1 = A_f V^3 \quad V^3 = A1V1 / A_f$

Case-2 Procedure for calculation of losses in feeders of single diameter with orifice [5, 6].

Channel No: North/South Design flow Q in Kg/hr

INLET FEEDER

Inlet Feeder Diameter and length are noted as in case-1

Diameter of orifice $D_o = \text{mm} = \text{m}$

OUT LET FEEDER

Inlet Feeder Diameter and length are noted as in case-1

Diameter of orifice $d_o = \text{in mm} = \text{in m}$

FRICION LOSS IN FEEDER

$h_f (D) = 4 f^* L^* V12 / 2^* g^* D$ where $f = 0.0008 + (0.05525 / (\text{Re})^{0.237})$
Re is Raynolds number (i)

INLET LOSSES

$$I_1 = h_i + h_o + h_b + h_{or} \quad (\text{ii})$$

h_i, h_o, h_b are calculated as in Case-1

Head loss in inlet orifice = h_{or}

Diameter of orifice $D_o = \text{mm} = \text{m}$

Area of orifice $A_o = \pi D_o^2/4 = \text{m}^2$

$$A1V1 = A_o V_{or}$$

$V_o =$ Velocity of water passing

through orifice

$$V_{or} = A1V1 / A_o$$

Velocity at vena Contracta $V_c = V_{or} / 0.62$

$$\text{Loss in orifices } h_{or} = [(V_c - V_{or})^2 / 2g]$$

OUTLET LOSSES

$$O_1 = h_i + h_o + h_b + h_{or}$$

(iii)

h_i, h_o, h_b are calculated as in Case-1

Head loss in outlet orifice = h_{or}

Diameter of orifice $d_o = \text{mm} = \text{m}$

Area of orifice $a_o = \pi d_o^2/4 = \text{m}^2$

$$A1V1 = a_o v_{or}$$

$V_{or} =$ Velocity of water passing

through orifice

$$v_{or} = A1V1 / a_o$$

Velocity at vena Contracta $v_c = v_{or} / 0.62$

$$\text{Loss in orifices} = [(v_c - v_{or})^2 / 2g]$$

HEAD LOSS IN FUEL PATH

is calculated as in case-1

(iv)

HEAD LOSS IN SHIELD PLUGS

H_{sp} is calculated as in case-1

(v)

Case-3 Procedure for calculation of losses in feeders of two different diameters without orifice. [5,6]

Channel: North/South

Design flow Q=Kg/hr

INLET FEEDER

First feeder diameter $D_1 = \text{mm} = \text{m}$ First feeder length

$L_1 = \text{mm} = \text{m}$

Second feeder diameter $D_2 = \text{mm} = \text{m}$ Second feeder length

$L_2 = \text{mm} = \text{m}$

No. of D_1 Bends $N_1 =$

No. of D_2 Bends $N_2 =$

OUT LET FEEDER

First feeder diameter

$d_1 = \text{mm} = \text{m}$ First feeder length $l_1 = \text{mm} = \text{m}$

Second feeder diameter

$d_2 = \text{mm} = \text{m}$ Second feeder length $l_2 = \text{mm} = \text{m}$

No. of d_1 Bends $n_1 = \text{nos}$

No. of d_2 Bends $n_2 = \text{nos}$

$$L_{d1D1} = L_1 + l_1 = \text{m}$$

$$L_{d2D2} = L_2 + l_2 = \text{m}$$

$$\text{Since } D_1 = d_1 \quad A_1 = \pi D_1^2/4$$

$$\text{Since } D_2 = d_2 \quad A_2 = \pi D_2^2/4$$

$$Q = A_1 V_1 = A_2 V_2 \quad V_2 = A_1 V_1 / A_2$$

$$Q' = (Q / 3600 * 885.4) \quad \text{m}^3/\text{s} \quad V = Q' * 4 / \pi D_1^2 \quad \text{m}/\text{s}$$

$$\gamma = \text{viscosity} = 0.01 * 10^{-4} = 10^{-6} \text{ Pa s}$$

Co-efficient of friction $f = 0.0008 + (0.05525 / (\text{Re})^{0.237})$ where $\text{Re} = (V D_1 / \gamma) = V D_1 / 10^{-6}$

Friction loss in Feeder of diameter D_1

$$h_f (D_1 d_1) = (4 f^* L_{d1D1}^* V^2) / 2^* g^* D_1$$

Friction loss in Feeder of diameter D_2

$$h_f (D_2 d_2) = (4 f^* L_{d2D2}^* V^2) / 2^* g^* D_2 \quad (\text{i})$$

Note: $V_2 = A_1 V_1 / A_2$

INLET LOSSES

$I_1 = h_i + h_e + h_o + h_{b1} + h_{b2}$ (ii)
 Feeder inlet loss $h_i = (0.5 V_1^2) / 2g$ Head loss when water enters the feeder from header
 Feeder expansion loss $h_e = (V_1 - V_2)^2 / 2g$ Head loss when feeder expands $V_2 = A_1 V_1 / A_2$
 Feeder exit or outlet loss $h_o = (V_2^2) / 2g$ Head loss when water exit the feeder $V_2 = A_1 V_1 / A_2$
 D1 Feeder bend loss $h(D_1 d_1) = [(0.1 V_1^2) / 2g] N_1$
 D2 Feeder bend loss $h(D_2 d_2) = [(0.1 V_2^2) / 2g] N_2$
 Note: $V_2 = A_1 V_1 / A_2$

OUTLET LOSSES

$O_1 = h_i + h_e + h_o + h_{b1} + h_{b2}$ (iii)
 Feeder inlet loss $h_i = (0.5 V_2^2) / 2g$ Head loss when water enters the feeder from channel
 Feeder contraction loss $h_c = (0.5 V_1^2) / 2g$ Head loss when feeder contract
 Feeder exit or outlet loss $h_o = (V_1^2) / 2g$ Head loss when water exit the feeder)
 d1 Feeder bend loss $h(D_1 d_1) = [(0.1 V_1^2) / 2g] n_1$
 d2 Feeder bend loss $h(D_2 d_2) = [(0.1 V_2^2) / 2g] n_2$

HEAD LOSS IN FUEL PATH

Diameter of fuel bundles pencils $d = 15.21 \text{ mm} = 0.01521 \text{ m}$
 $A_d = \pi d^2 / 4 = m^2$
 Diameter of fuel bundles $D = 82.5 \text{ mm} = 0.0825 \text{ m}$
 $A_D = \pi D^2 / 4 = m^2$
 Length of the fuel column $L = 6000 \text{ mm} = 6 \text{ m}$
 Area for water flow $(A_D - A_d)$ $A_f = 0.00192 \text{ m}^2$
 $h_f (\text{fuel}) = [f / 2 (\pi d^{19} + \pi D) * 2L * V^3] / A_f * g$ (iv)
 Note: $A_1 V_1 = A_f V_3$ $V_3 = A_1 V_1 / A_f$

HEAD LOSS IN SHIELD PLUGS

$H_{sp} = [\text{Inlet Bend Loss}(a) + h_f (b) + \text{Loss in holes}(c) + \text{Outlet Bend Loss}(d)] * 2$ (v)
 Inlet Bend Loss = $(0.1 V_2^2) / 2g$ (a)
 Outer diameter of liner tube $d = 90.6 \text{ mm} = 0.0906 \text{ m}$
 $a_{sp} = \pi d^2 / 4 = m^2$
 Inner diameter of end fitting $D = 107.57 \text{ mm} = 0.10757 \text{ m}$
 $A_{sp} = \pi D^2 / 4 = m^2$
 Length of liner tube $L_s = 1850 \text{ mm} = 1.85 \text{ m}$
 Area for water flow $A_{sd} = A_{sp} - a_{sp} = m^2$
 $A_1 V_1 = A_{sp} V_4$
 $h_{f1} = [f / 2 (\pi d + \pi D) * 2L_s * V_4^2] / A_{sp} * g$ (b)
 Note: $V_4 = A_1 V_1 / A_{sp}$
 Diameter of holes in the shield plug
 $d_h - \text{ø of hole} = 12.7 \text{ mm} = 0.0127 \text{ m}$
 $A_h = \pi d_h^2 / 4$ $A_1 V_1 = A_h V_h$ $V_h = A_1 V_1 / A_h$
 V_h -Velocity of water passing through hole
 Velocity at vena Contracta $V_c = V_h / 0.62$
 Loss in holes = $[(V_c - V_h)^2 / 2g] * 52$ (c)

Outlet Bend Loss = $(0.1 V_3^2) / 2g$ (d)
 Note: $A_1 V_1 = A_f V_3$ $V_3 = A_1 V_1 / A_f$

Case-4 Procedure for calculating feeders of two different diameters with orifice. [5,6]

Channel: North/South Design flow $Q = K_g / \text{hr}$

INLET FEEDER

Inlet Feeder Diameter and length are noted as in case-3
 Diameter of orifice $D_o = \text{mm} = m$

OUT LET FEEDER

Inlet Feeder Diameter and length are noted as in case-3
 Diameter of orifice $D_o = \text{mm} = m$
 $L_{d1D1} = L_1 + l_1 = m$
 $L_{d2D2} = L_2 + l_2 = m$
 Since $D_1 = d_1$ $A_1 = \pi D_1^2 / 4$
 Since $D_2 = d_2$ $A_2 = \pi D_2^2 / 4$
 $Q = A_1 V_1 = A_2 V_2$ $V_2 = A_1 V_1 / A_2$
 $Q' = (Q / 3600 * 885.4) \text{ m}^3 / \text{s}$ $V = Q' * 4 / \pi D^2 \text{ m/s}$
 Co-efficient of friction f , Friction loss in Feeder of diameter D_1 and diameter D_2 are calculated as in case-3
 Friction loss in Feeder of diameter D_1 $h_f (D_1 d_1) = (4 f * L_{d1D1} * V_1^2) / 2 * g * D_1$
 Friction loss in Feeder of diameter D_2 $h_f (D_2 d_2) = (4 f * L_{d2D2} * V_2^2) / 2 * g * D_2$ (i)

INLET LOSSES

$I_1 = h_i + h_e + h_o + h_{b1} + h_{b2} + h_{or}$ (ii)
 $h_i, h_e, h_o, h_{b1}, h_{b2}$ are calculated as in case-3
 Head loss in inlet orifice = h_{or} is calculated as in case-2

OUTLET LOSSES

$O_1 = h_i + h_e + h_o + h_{b1} + h_{b2} + h_{or}$ (iii)
 $h_i, h_e, h_o, h_{b1}, h_{b2}$ are calculated as in Case-3
 Head loss in outlet orifice = h_{or} is calculated as in case-3

HEAD LOSS IN FUEL PATH

$h_f (\text{fuel}) = [f / 2 (\pi d^{19} + \pi D) * 2L * V^3] / A_f * g$ (iv)
 is calculated as in Case-3

HEAD LOSS IN SHIELD PLUGS

is calculated as in case-3
 $H_{sp} = [\text{Inlet Bend Loss}(a) + h_f (b) + \text{Loss in holes}(c) + \text{Outlet Bend Loss}(d)] * 2$ (v)
 Inlet Bend Loss = $(0.1 V_2^2) / 2g$ (a)
 Outer diameter of liner tube $d = 90.6 \text{ mm} = 0.0906 \text{ m}$
 $a_{sp} = \pi d^2 / 4 = m^2$
 Inner diameter of end fitting $D = 107.57 \text{ mm} = 0.10757 \text{ m}$
 $A_{sp} = \pi D^2 / 4 = m^2$
 Length of liner tube $L_s = 1850 \text{ mm} = 1.85 \text{ m}$

Area for water flow $A_{sd}=A_{sp}-a_{sp}=m^2$
 $A_1V_1=A_{sp}V_4$
 $hf_1= \left[\frac{f}{2}(\frac{m}{d}+ \frac{m}{D}) \right] * 2Ls * V_4^2 / A_s * g$ (b)
 Note: $V_4= A_1V_1/A_{sp}$

Fig-5 Design flow through the core expected

Diameter of holes in the shield plug $d_h= \phi$ of hole-12.7mm = 0.0127m

$A_h= \pi d_h^2 / 4$ $A_1V_1=A_h V_h$ $V_h= A_1V_1/A_h$

V_h -Velocity of water passing through hole

Velocity at vena Contracta $V_c=V_h/0.62$

Loss in holes = $[(V_c- V_h)^2/2g]*52$ (c)

Outlet Bend Loss = $(0.1 V^3)/2g$ (d)

Note: $A_1V_1=A_fV_3$ $V_3= A_1V_1/A_f$

Flow Calculation

Total Loss $(T_L)=(i)+(ii)+(iii)+(iv)+(v)$

as calculated in all the 4 cases. I/L Header Pressure $I_p=Kg/Cm^2$

O/L Header Pressure $O_p= Kg/Cm^2$

$\Delta P= I_p - O_p$ Kg/Cm^2

$(\Delta P/\sigma) = T_L=V_1^2*0.89$

$V_1^2=T_L/0.89$

$V_1= \sqrt{(T_L/0.89)} = (\Delta P/\sigma)$

Actual Flow is calculated using the formula:

$Q_{Actual}=V_1*A_1*3600*885.4$

The actual flow calculated is compared with design flow as shown in Fig-5 and the result found is within 5% tolerance.

7.2 ACKNOWLEDGMENTS

This work is done in coordination with the Nuclear Power Corporation India Limited, Kaiga Generating Station Staff and Management. Authors are Thankful Mr.Deepak M.Pai, Mr.Ratnakar Pandit, Mr.B.Vinodkumar (Operation Superintendent Kaiga Generating station)Mr.H.N.Bhat (Station Director KGS) to have the project realistic and working successfully and to meet our expectation. We highly appreciate the efforts of the management to use this as a tool for safe operation. We are also thankful for all the readers and highly appreciate suggestions for enhancing the performance of the system.

5.0 CONCLUSION

It has been found from analysis that flow calculated matches with the design flow through the individual channel within the tolerance of $\pm 5\%$. The flow calculated for different header pressures and the result is compared with the flow calculated in the instrumented channels and the flow calculated in the commissioning procedures at various header pressures. The calculated flow matches with the commissioning procedure flow within the tolerance of $\pm 5\%$.

REFERENCES

- [1] Design Manual on CFM System Project KGS1&2 Rev 2 Jan-1997..
- [2] Operating Manual for PHT main system Kaiga Generating Station Rev-3.2 Jan-11.
- [3] Design Manual on CFM Instrumentation and Controls System Project KGS3&4 Rev 2 Apr-2007.
- [4] Design Manual on Feeders Headers and Primary coolant distribution in the core KGS1&2 Rev-1 Jan98
- [5] Kaiga Generating Station System Design Drawing KAIGA-1&2/33110/2003&2004/GA.
- [6] Kaiga Generating Station System Design Drawing KAIGA-1&2/33117/2004&2005/DD
- [7] Design Manual on 19 element Fuel Bundles Project KGS1&2 Rev 2 Apr-2009
- [8] REACTOR PHYSICS PROCEDURES Project KGS1&2 Rev 4 Mar-2011